

I-26-EM-J

FLUORESCENT EMERGENCY BALLAST

OPTIONS

CONFIGURATION

TWO-PIECE TEST SWITCH AND CHARGE INDICATOR

SPECIALTY

DL - DAMP LOCATION

VOLTAGE RATINGS

120/277V 60HZ (STANDARD)

220V 50HZ

240V 60HZ

120V 50HZ

AVERAGE LUMEN RATINGS

LAMP	1 LAMP
18W PL CF 2-pin	550
26W PL CF 2-pin	650

REMOTE MOUNTING

When battery packs are remote mounted, the remote distance can not exceed $\frac{1}{2}$ of the distance from ballast to lamp specified by the A.C. ballast manufacturer. For example, if the A.C. ballast manufacturer recommends no more than 25' remote distance, then the battery pack should not exceed 12 $\frac{1}{2}$ '. The maximum allowable remote mounting distance is 50' from the lamp.