

MOUNTING SPECIFICATIONS

DLS MODELS:

DLS-UI-27-40-PFC

PROVIDE PROPER CLEARANCE FOR AIR INTAKE TO FAN

RECOMMENDED CLEARANCE
IS 4" OF CLEARANCE ON FAN END
AND 2-3" OF CLEARANCE ON ALL
OTHER SIDES

